SQUARE 1





Circuit breaker, FA, 600V, 30A, 3 pole

FAF36030V35

- ! Discontinued on: Oct 31, 2020
- ! End-of-service on: Dec 31, 2020

① Discontinued

Main

Product Or Component Type	Circuit breaker
Trip Unit Technology	Thermal-magnetic

Complementary

Line Rated Current	30 A	
Number Of Poles	3P	
Breaking Capacity Code	A	
Mounting Mode	Unit mount	
Magnetic Hold Current	275 A	
Magnetic Tripping Current	600 A	
Electrical Connection	Busbar connection, line Busbar connection, load	
Phase Connection	ABC	
Height	6.4 in (162.56 mm)	
Width	4.5 in (114.30 mm)	
Depth	4.13 in (104.90 mm)	
Circuit Breaker Application	HACR rated	

Environment

Certifications	CSA
	UL Listed

Ordering and shipping details

Category	00903-FAL/FHL 600V	
Category	00903-FAL/FRL 000V	
Discount Schedule	DE2	
Gtin	00785901776901	
Returnability	No	
Country Of Origin	MX	

Packing Units

Unit Type Of Package 1	PCE
Number Of Units In Backage 1	

Price is "List Price" and may be subject to a trade discount – check with your local distributor or retailer for actual price.

Contractual warranty

Warranty

18 months



Green PremiumTM **label** is Schneider Electric's commitment to delivering products with best-inclass environmental performance. Green Premium promises compliance with the latest regulations, transparency on environmental impacts, as well as circular and low-CO₂ products.

Guide to assessing product sustainability is a white paper that clarifies global eco-label standards and how to interpret environmental declarations.

Learn more about Green Premium >

Guide to assess a product's sustainability >





Transparency RoHS/REACh

Well-being performance



Mercury Free



Rohs Exemption Information

Yes

Certifications & Standards

Eu Rohs Directive	Not applicable, out of EU RoHS legal scope EU RoHS Declaration
China Rohs Regulation	China RoHS declaration Product out of China RoHS scope. Substance declaration for your information.
Environmental Disclosure	Product Environmental Profile
California Proposition 65	WARNING: This product can expose you to chemicals including: DINP, which is known to the State of California to cause cancer, and DIDP, which is known to the State of California to cause Birth Defects or other reproductive harm.For more information go to www.p65warnings.ca.gov