

LDL46250U33X

PowerPact L Circuit Breaker, Micrologic3.3S, 250A, 4P, 600V, 14kA

Product availability : Non-Stock - Not normally stocked in distribution facility



Price* : 5,891.00 USD



Main

| | |
|---------------------------|--|
| Product or component type | Circuit breaker |
| Range of product | PowerPact L |
| Trip Unit Type | Electronic standard Micrologic 3.3 S LSI |
| Interrupt Code | D |

Complementary

| | |
|---------------------------|--|
| Protection technology | Current limiter |
| Line Rated Current | 250 A |
| Number of Poles | 4P |
| Interrupt Rating | 18 kA at 480 V AC 25 kA at 240 V AC 14 kA at 600 V AC |
| System Voltage | 600 V AC |
| Continuous current rating | 80 % |
| Mounting mode | Unit mount |
| Electrical connection | Lugs load Lugs line |
| Wire Size | AWG 2...500 kcmil (aluminium) 1(cable(s)) AWG 2...600 kcmil (copper) 1(cable(s)) |
| Terminal Type | AL400L61K4 |
| Height | 13.39 in |
| Width | 7.27 in |
| Depth | 6.61 in |
| Tightening torque | 37...50 N.m AWG 2...500 kcmil 37...50 N.m 35...240 mm ² AWG 2...500 kcmil 37...50 N.m 35...300 mm ² AWG 2...600 kcmil 37...50 N.m AWG 2...600 kcmil |

Environment

| | |
|------------------------|--------------------------------------|
| Product certifications | CCC CE CSA UL listed NMX |
|------------------------|--------------------------------------|

Ordering and shipping details

| | |
|-----------------------|---|
| Category | 01116 - L ELEC TRIP UNIT MOUNT BREAKER/SW |
| Discount Schedule | DE2 |
| Nbr. of units in pkg. | 1 |
| Package weight(Lbs) | 17 |
| Returnability | Y |
| Country of origin | US |

Offer Sustainability

| | |
|---------------------------|---|
| RoHS (date code: YYWW) | Compliant - since 1132 - Schneider Electric declaration of conformity Schneider Electric declaration of conformity |
| REACH | Reference not containing SVHC above the threshold Reference not containing SVHC above the threshold |
| California proposition 65 | WARNING: This product can expose you to chemicals including: |
| ----- Substance 1 | DINP, which is known to the State of California to cause cancer, and |
| ----- Substance 2 | DIDP, which is known to the State of California to cause Birth Defects or other reproductive harm. |
| ----- More information | For more information go to www.p65warnings.ca.gov |

Contractual warranty

| | |
|-----------------|-----------|
| Warranty period | 18 months |
|-----------------|-----------|